



ADDENDUM NO.: 7

IFB or RFP NO.: 742

Description: Furnish, Deliver and Install AV Equipment

Project: SUNY Fashion Institute of Technology

Bid Opening Date: Friday, March 24, 2023, at 3:00PM

Specifics of the Addendum: Answer questions received during RFI period.

1. Q: Please confirm: Knitting Lab – Missing Gooseneck Microphone (MIC40) MX418/C) Qty.1
A: Contractor to follow equipment list and provide the specified gooseneck microphone for the podiums.
2. Q: Please confirm: Knitting Lab – Addition Wireless receiver (WMS01) (ULXD4) Qty. 1
A: Contractor to follow equipment list. The Knitting Lab requires (1) Shure QLXD-14/93 wireless microphone receiver and lavalier microphone / bodypack transmitter.
3. Q: Please confirm: Knitting Lab – Replaced HDBT transmitter (HDTX2) (HDMI-TPS-TX210) to unknown item (HDA01) Qty. 1, AV consultant SYSTEM ID is missing, please provide.
A: SMW Response: HAD01 to be HDMI 2x1 DA -- Extron DA2 HD 4K / 60-1480-01
4. Q: Please confirm: Classrooms / Workshop Classrooms – Replaced gooseneck Mic (MIC40) (MX418/C) to lavalier MIC (WMS02) (QLXD14/93) Qty. 24
A: Contractor to follow equipment list and provide the specified gooseneck microphone for the podium in each room.
5. Q: Please confirm: Classrooms / Workshop Classrooms – Replaced lavalier MIC (WMS02) (QLXD14/93) to Wireless receiver (WMS01) (ULXD4) Qty. 24
A: Contractor to follow equipment list. The Each room requires (1) Shure QLXD-14/93 wireless microphone receiver and lavalier microphone / bodypack transmitter.
6. Q: Please confirm: Classrooms / Workshop Classrooms – Replaced HDBT transmitter (HDTX2) (HDMI-TPS-TX210) to unknown item (HDA01) Qty. 24, AV consultant SYSTEM ID is missing, please provide.
A: HAD01 to be HDMI 2x1 DA -- Extron DA2 HD 4K / 60-1480-01
7. Q: With respect to AV equipment that will be installed in the podium, does that podium include a 19" rack rail or not, if not, who will provide it.
A: Podiums do not include a rack rail. The equipment itself is not rack mountable. Equipment is to be secured to interior podium structure – surface mounted.

8. Q: How will we find out who is responsible for providing Crestron items?
A: Crestron equipment and further information will be sent to the installer once awarded.

9. Q: Please advise responsibility matrix for all OFCI (owner furnished contractor installed) such as (Programming-commissioning-Testing-Warranty).
A: Please refer to the scope of work.

All other terms and conditions of the original Invitation for Bids shall remain the same.